

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. *7136-1591:150 Page 1 of 1

CATEGORY: Audible Devices for Hazardous Locations

LISTEE: Edwards Systems Technology, 6411 Parkland Drive, Sarasota, FL 34243
Contact: Leon Newsome (941) 739-4276 FAX (941) 739-4334

DESIGN: Models 325, 340, 340T, 343, 438, 439, 439D series and explosion-proof Models CS2315, CS2316 and 340DEX, 435DEX, 438DEX, 439DEX series vibrating bells. Models 325, 340, 340T, 343, 438, 439, 439D may be used outdoors when used with a weatherproof box. Refer to listee's data sheet for detailed model description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, hazardous location classification (if applicable) and UL label.

APPROVAL: Listed as audible devices for use with separately listed compatible control units. Explosion-proof models intended for use in Class I, Groups B,C,D; Class II, Groups E,F,G hazardous locations.

If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

NOTE: Formerly 7135-0073:032, 7135-1388:110 and *7135-1591:150

*Rev. 031-0-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **MARCH 10, 2004**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**